


## Reservedele for QTS OM elektriske aktuatorer

Varenummer	Part no	Beskrivelse
40709077	SCF00005A	Potentiometer: 1kOhm - OM2-8, modulating, 30% duty cycle
40709060	SCF00008A	Potentiometer: 1kOhm - OM2-8, modulating, 75% duty cycle
40709078	SCF00013A	Potentiometer: 5kOhm - OM7-8, modulating, 30% duty cycle
40709074	SCF00016A	Potentiometer: 5kOhm - OM2-8, modulating, 75% duty cycle

40707779	MBF0700051B	Printkort /Modulating board: OM2-8 110/220 30% duty cycle
40708459	MBF0700059B	Printkort /Modulating board: OM2-8 110/220 75% duty cycle


75% Duty cycle modulating c




30% Duty cycle modulating card



40707780	MBF0700012A	Printkort/Electric Board: 75% duty cycle (Actuator med 2 printkort)
----------	-------------	---



75% modulating card



old type



new type

## Test potentiometer

### Test VR:

STEP 1. Take off the terminal 6、7、8、9、10.



STEP 2. Turn the handwheel in full open or full closed.

STEP 3. Use the multimeters to check if the resistance variation is in regular in terminal(8)、(9)&(9)、(10).

Please check if the value is from "OK(normal)" to "5K" or "5K" TO" OK(normal).

